



**NOTES:**

1. EACH VALVE SHALL BE PROVIDED WITH THE FOLLOWING OLYMPIC FOUNDRY VALVE BOX PARTS OR APPROVED EQUALS; LID PART NO. 13-5010, TOP PART NO. 13-5020, & BASE PART NO. 13-5021.
2. 15" MINIMUM, 36" MAXIMUM FOR OPERATOR NUT. EXTENSION MAY BE REQUIRED, SEE DETAIL W19.
3. AS REQUIRED BY THE CITY, A VALVE MARKER POST PER DETAIL W24 SHALL BE INSTALLED WITH THE VALVE BOX IN UNIMPROVED AREAS.
4. VALVE BOX SHALL BE CENTERED ON VALVE.

Approved:

City Engineer

March 16, 2018

Date

**WATER STANDARD DETAIL**



Dwg No:

**W16**

**VALVE BOX**