



**NOTES:**

1. TRENCH SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH WSDOT 7-09.3(10) & (11) OR AS APPROVED IN WRITING BY THE CITY ENGINEER.
2. PIPE ZONE BEDDING SHALL BE GRAVEL BACKFILL FOR PIPE ZONE BEDDING IN ACCORDANCE WITH WSDOT 9-03.12(3) OR AS APPROVED IN WRITING BY THE CITY ENGINEER.
3. FOR EXISTING ROADS, BACKFILL MATERIAL ABOVE THE PIPE ZONE SHALL BE 1½" CRUSHED ROCK. FOR NEW ROAD CONSTRUCTION, BACKFILL MATERIAL ABOVE THE PIPE ZONE SHALL BE GRAVEL BORROW OR SELECT BORROW IN ACCORDANCE WITH WSDOT 9-03.14 OR 1½" CRUSHED ROCK OR AS APPROVED IN WRITING BY THE CITY ENGINEER.

Approved:

March 16, 2018

City Engineer

Date

**WATER STANDARD DETAIL**



Dwg No:

**W2**

**WATER MAIN  
TRENCH SECTION**