



NOTES:

1. VALVE MARKER POST SHALL BE WHITE IN COLOR.
2. THE DISTANCE FROM THE MARKER POST TO THE WATER MAIN SHALL BE STENCILED ON THE BACKSIDE OF THE MARKER POST IN BLACK PAINT TO THE NEAREST FOOT AND 2" TALL.
3. VALVE MARKER POST SHALL BE REQUIRED WHEN A WATER VALVE IS LOCATED IN AN UNPAVED AREA.
4. POST SHALL BE REQUIRED FOR BLOW-OFF ASSEMBLIES IN THE SAME CONDITION AS WATER VALVES.
5. LOCATION OF VALVE MARKER POSTS SHALL BE OFFSET AT RIGHT ANGLES TO EACH LINE VALVE.

Approved:

March 16, 2018

City Engineer

Date

**WATER STANDARD DETAIL**



Dwg No:

**W24**

**VALVE MARKER POST**