



### DUCTILE IRON TAPPING TEE MECHANICAL JOINT SLEEVE

INSTALLED ON ASBESTOS CEMENT PIPE,  
CAST IRON PIPE AND DUCTILE IRON PIPE.

#### NOTES:

1. STAINLESS STEEL TAPPING TEES SHALL HAVE FULL CIRCLE SEAL. BOLTS AND NUTS SHALL BE STAINLESS STEEL.
2. STEEL TAPPING TEES SHALL BE EPOXY COATED. BOLTS AND NUTS SHALL BE COR-TEN, OR STAINLESS STEEL.
3. ALL TEES AND VALVES TO BE WATER TESTED BEFORE TAP.
4. TAPPING TEE MAY BE SIZE ON SIZE. TAP SHALL BE AT LEAST 2" SMALLER DIAMETER THAN THE EXISTING MAIN.

### STAINLESS STEEL OR STEEL TAPPING TEE

#### STAINLESS STEEL TAPPING TEE

INSTALLED ON ASBESTOS CEMENT PIPE,  
CAST IRON PIPE AND DUCTILE IRON  
PIPE.

#### STEEL TAPPING TEE

INSTALLED ON DUCTILE IRON PIPE ONLY.

#### SPECIAL NOTE:

OPERATION SHALL BE BY CITY PERSONNEL ONLY.  
CONTRACTOR SHALL NOT OPERATE VALVE

Approved: \_\_\_\_\_

March 16, 2018

City Engineer

Date

**WATER STANDARD DETAIL**



Dwg No:

**W6**

**WET TAP  
CONNECTION**