

Water Use Efficiency Annual Performance Report - 2018

WS Name: BONNEY LAKE WATER DEPARTMENT CITY

Water System ID# : 07650 WS County: PIERCE

Report submitted by: David Cihak

Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not 100% metered – Did you submit a meter installation plan to DOH? No

Within your meter installation plan, what date did you commit to completing meter installation?

Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period 01/01/2018 To 12/31/2018

Incomplete or missing data for the year? No

If yes, explain:

Total Water Produced & Purchased (TP) – Annual volume gallons 1,307,096,000 gallons

Authorized Consumption (AC) – Annual Volume in gallons 1,195,196,057 gallons

Distribution System Leakage – Annual Volume TP – AC 111,899,943 gallons

Distribution System Leakage – DSL = $[(TP - AC) / TP] \times 100 \%$ 8.6 %

3-year annual average - % 8.7 % 2016, 2017, 2018

Goal-Setting Information:

Enter the date of most recent public forum to establish WUE goal: 03/03/2018

Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process.

Customer WUE Goal (Demand Side):

Achieve additional system wide average water use reduction of 5% by the year 2010 and 10% by the year 2024 with 2004 as the base year. Increase awareness among all water users of the value and importance of conserving water and all of the methods available to achieve reductions in water use.

Customer (Demand Side) Goal Progress:

The initial baseline per capita consumption in 2004 was 100 gpd. In 2018 the per capita consumption was 86 gpd. The five year average per capita consumption is 86 gpd. The City continues to educate customers, and encourage conservation through the annual Consumer Confidence Report, utility bill stuffers, printed news sources, and social media outlets including the City website, Facebook page, and City blog. The City continues to provide customers with water consumption history on their utility bills, and notifies customers of higher than normal consumption during monthly reading and billing cycles. The City continues to use a four tier rate structure during high demand summer months, and a two tier rate structure during the winter months. With the City's continued efforts to implement an AMR/AMI metering system, the City is able to provide customers with detailed account information and educate them on how and when their water is used. The City also conducts an annual leak detection survey and alerts customers of service line leaks detected during the survey.

Additional Information Regarding Supply and Demand Side WUE Efforts

In 2018 the City saw a slight increase in the DSL from 8.33% in 2017 up to 8.56% in 2018. The City continues to budget \$200-275,000 annually to replace water meters with newer AMR meters. The budgeted amount allows for the replacement of approximately 10% of the total meters annually. The City continues to aggressively follow up on 'zero consumption' meters identified during monthly read cycles, and replaces any meter found to be faulty. The City also continues to conduct an annual leak detection survey covering approximately 20-25% of the total distribution system. This survey is a 'point to point' survey that listens to all appurtenances including individual service lines, meters, fire hydrants, valves, blow offs, and air vacs. City staff immediately perform repairs as leaks are identified. The City continues to analyze data related to water main failures and is scheduling these for replacements based on these results, as budgetary limitations allow.

Describe Progress in Reaching Goals:

- Estimate how much water you saved.
- Report progress toward meeting goals within your established timeframe.
- Identify any WUE measures you are currently implementing.
- If you established a goal to maintain a historic level (such as maintaining daily consumption at 65 gallons per person per day for the next two years) you must explain why you are unable to reduce water use below that level.

The following questions will help DOH better understand water usage, water resources management and drought response. The data will be used to provide technical assistance, not for regulatory purposes.

All questions are voluntary

Month	Date of Measurement	Static Water Level (feet below measuring point)	Dynamic Water Level (feet below measuring point)
January			
February			
March			
April			
May			
June			
July			
August			
September			
October			
November			
December			

Water level data:

Please provide the following information (if known) to help us better utilize the water level data.

Well tag Id number:

Well depth:

Water level accuracy (within 0.01 ft < 1 ft ~ 1 ft)

Completion type (e.g., cased open interval, cased open-ended, cased open-ended with perforations, etc...)

Location coordinates (latitude, longitude) and accuracy of the coordinates (< 1ft, ~1ft, >1000ft)

Water level parameter name (e.g. depth below measuring point, depth below top of casing, depth below ground surface)

Elevation of top of casing OR elevation of measuring point if different than top of casing (as specified in question 7)

Monthly/Seasonal Water Usage:

What was your maximum daily water demand for the previous year (in gallons per day)? _____

Month	Volume of Water Produced in gallons
January	
February	
March	
April	
May	
June	
July	
August	
September	
October	
November	
December	

Water shortage response:

Did you activate any level of water shortage response plan the previous year?

- ☐ Yes ☐ No ☐ There was no need to

If you activated a water shortage response plan the previous year, what level did you activate? (Check all that apply)

- ☐ Advisory Conservation ☐ Voluntary Conservation
☐ Mandatory Conservation ☐ Rationing ☐ Other

What factors caused your water shortage the previous year?

- ☐ Drought ☐ Fire ☐ Landslides ☐ Earthquakes
☐ Flooding ☐ Water Supply Limitations ☐ Other

Do not mail, fax, or email this report to DOH